


PW/B36-HD

Placer Waterworks, Inc.
1325 Furneaux Road
Plumas Lake, CA. 95961
(530) 742-9675



THE REINFORCED CONSTRUCTION OF THIS COVER HAS BE DESTRUCTIVELY TESTED TO 46,930 psi. WHICH CREATED 1/2" PERMANATE DEFLECTION. TESTED AT CAPITAL ENGINEERING LABORATORIES ROSEVILLE, CA. JUNE 21, 1999