

PDCU
Placer Waterworks Inc.
1325 Furneaux Road
Plumas Lake, CA. 95961
(530) 742-9675

1/8" Steel Plate Weled
to 1 3/8"Ø Bar

2" x 2"
Operator Nut

Univeral Joint

Set Screw

1/2" x 5/8" Poly-Uerthane
Ring to provide a
slippery surface assisting
the valve for ease in
operation because of
virtually minimal
resistance.

2" Valve Operator Socket

* Diameter of Poly-Urethane Ring 7 1/2"

The Polyurethane Centering Device Universal is utilized when the riser pipe is out of plumb to the water valve. Available for 8" riser pipes.

Maximum operation at 45°

Max. torque of 10,000 in.lb

This drawing must be signed and returned
returned to Placer Waterworks Inc. when
order is placed and before work is started.